

महाराष्ट्र राज्य सार्वजनिक आरोग्य सेवा
जिल्हा आरोग्य प्रयोगशाळा जळगांव

दूरध्वनी क्र.0250-2229229

E-mail : dphjal@gmail.com

पाणी नमुन्याचा सूक्ष्मजीवीय अहवाल

प्रति, ✓ Principal Oxford English Medium School Chopda (Jalgaon)
पाठविणान्यांचे पत्र क्रमांक व दिनांक :- 125 / 15 16-01-23
प्रयोगशाळा संदर्भ क्रमांक :- 360
नमुना घेतल्याचा दिनांक :-
नमुना पोहचल्याचा दिनांक :- 16-01-23
परीक्षण सुरु केल्याचा दिनांक :- 16-01-23

अ. क्र.	नमुन्याचे विवरण	परीक्षणाचे निष्कर्ष			इतर अभिप्राय
		प्रती 100 मि.ली. नमुन्यातील संभाव्य सूक्ष्मजंतूंची संख्या			
		कोलीफॉर्मस	थर्मोटॉलरंट कोलीफॉर्मस	इ. कोलाय	
1)	आर.डी. पाणी नमुना प्लान नंबर - 805605 दिनांक - 16-01-23 अहवाल - 360	16 परीक्षा घेतली	09	—	पिण्यास अयोग्य
टीप - सदर पाणी नमुना या प्रयोगशाळेतून गोळा केल्यात आलेले नाही.					

अभिप्राय :- पिण्यास अयोग्य पाण्यावर योग्य प्रमाणात क्लोरिनची प्रक्रिया केल्यानंतर व सूक्ष्मजीवीय पुनर्तपासणीनंतर पिण्यास योग्य असल्याची खात्री झाल्यानंतर ते पाणी पिण्यासाठी वापरता येईल.

अहवाल क्रमांक : 205
अभिप्राय तारखेने कळविण्यात दिनांक :

दिनांक :- 20-01-2023

प्रत सादर :

- (1) जिल्हा आरोग्य अधिकारी जिल्हा परिषद जिल्हा
- (2) शल्यचिकित्सक, जिल्हा रुग्णालय जिल्हा
- (3) गटविकास अधिकारी पंचायत समिती

Indul
Junior Scientific Officer
District Public Health Laboratory
Jalgaon - 425 001
U J Pradip

State / Regional / District / Sub Divisional Public Health Laboratory, JalgaonE-mail-ID : dph1jal@gmail.comPhone No. : 2229221

REPORT ON CHEMICAL EXAMINATION OF WATER FOR DRINKING PURPOSES

Date of Collection : — — Date of Receipt :— 26/12/2022 Date of Examination :— 26/12/2022

(All the Analytical Results are in mg./Litre except pH, Turbidity)

Forwarded.

Sr. No.	TEST PARAMETER	(1) <u>School</u> <u>R.O.</u>	(2)	(3)	BIS Specification 10500 : 2012 Normal Values	
					Desirable Limits	Permissible Limits
1.	Physical Appearance	<u>clear</u>			—	—
2.	Odour	<u>odour free</u>			Agreeable	Agreeable
3.	Turbidity (as N.T.U.)	<u>0.27</u>			1.0	5.0
4.	pH Value	<u>8.43</u>			6.5 to 8.5	No relaxation
5.	Chlorides (as Cl)	<u>11.99</u>			250	1000
6.	Nitrates (as NO ₃)	<u>0.020</u>			45	No relaxation
7.	Total Hardness (as CaCO ₃)	<u>51.6</u>			200	600
8.	Alkalinity (as CaCO ₃)	<u>41.4</u>			200	600
9.	Total Dissolved Solids	<u>105.0</u>			500	2000
10.	Iron (as Fe)	<u>0.06</u>			0.3	No relaxation
11.	Fluoride (as F)	<u>0.124</u>			1.0	1.5
12.	Other Tests (if any)	<u>—</u>				
13.						
14.						
15.						
16.						
17.						
18.						
19.						
20.						

- This report is restricted only for the Sample/s is Submitted to this Laboratory.
- This Sample/s is / are not Collected by this Laboratory.

[P.T.O.]

REMARKS

✓ A) Sample No. (s) 01 is/are potable / chemically fit for drinking purpose on the basis of analysed parameters only.

However, this / these water source/s can be used for drinking purpose only after proper treatment, disinfection and ascertaining it's bacteriological quality frequently or regularly.

B) Sample No. (s) — Contains _____

However, if there is no any other alternate source available nearby then this / these water Source/s can be used for drinking purpose only after proper treatment, disinfection and ascertaining it's bacteriological quality frequently or regularly.

C) Sample No. (s) — Contains _____

Hence, this / these water Source/s is / are chemically non-potable / unfit for drinking purpose on the basis of analysed parameters only.

HEALTH SERVICES

No. DPHL/Jal/A/45/46 /2022

Date :- 03-01-2023

Forwarded With Compliments To : The principal

M.G.S. M'S Oxford Eng. Med school

Tal. chopada

Dist. Talgaon

With reference to letter No. : 104/2022-23 Dated :- 26/12/2022

Fees Rs. : 600/-

Receipt No. and Date : 9898970
26/12/2022

Includes :
Junior Scientific Officer
District Public Health Laboratory
Talgaon - 425 001
(S. J. Padhi)



SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

O/W.No. 480

Date : 28/5/2023

It is certified that an inspection team headed by Vikas Kadu Patil, Sanitary inspector Municipal Corporation, Chopda Dist. Jalgaon inspected Mahatma Gandhi Shikshan Mandal Sanchalit Oxford English Medium School, Gat No.1136, Arts, Science and Commerce College Campus, Chopda Dist. Jalgaon On 03/05/2023 and found that Mahatma Gandhi Shikshan Mandal Sanchalit Oxford English Medium School, Chopda Dist. Jalgaon has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T. Govt.

The above valid for a period of three years.

Signature with Seal 


Name : Vikas Kadu Patil

Designation : Sanitary Inspector

To,

Mahatma Gandhi Shikshan Mandal Sanchalit,

Oxford English Medium School,

Chopda Dist. Jalgaon.