

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE



O/W.No. 480

Date : 28/5/2023

It is certified that an inspection team headed by Vikas Kadu Patil, Sanitary inspector Municipal Corporation, Chopda Dist. Jalgaon inspected Mahatma Gandhi Shikshan Mandal Sanchalit Oxford English Medium School, Gat No.1136, Arts, Science and Commerce College Campus, Chopda Dist. Jalgaon On 03/05/2023 and found that Mahatma Gandhi Shikshan Mandal Sanchalit Oxford English Medium School, Chopda Dist. Jalgaon has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T. Govt.

The above valid for a period of three years.

Signature with Seal

Name : Vikas Kadu Patil

Designation : Sanitary Inspector

To,

Mahatma Gandhi Shikshan Mandal Sanchalit,
Oxford English Medium School,
Chopda Dist. Jalgaon.





Government of Maharashtra Health Services

District Public Health Laboratory, Jalgaon

E-mail ID dphljal@gmail.com

Phone No (0257) 2229221

Report on Chemical Examination of Water for Drinking Purposes

Date of Collection:- —

Date of Receipt:- 29/05/2025 Date of Examination :- 29/5/2025 onwards.

(All the Analytical Results are in mg. / Lit. except pH, Turbidity)

Sr. No.	TEST PARAMETER	(1) School R.O.	(2)	(3)	BIS Specifications 10500 : 2012 Normal Values	
					Desirable Limits	Permissible Limits
1	Physical Appearance	clear			---	---
2	Odour	odour free			Agreeable	Agreeable
3	Turbidity (as N.T.U.)	0.32			1.0	5.0
4	pH Value	6.1			6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	65.0			250	1000
6	Nitrates (as NO_3)	0.0			45	No relaxation
7	Total Hardness (as CaCO_3)	130.0			200	600
8	Alkalinity (as CaCO_3)	50.0			200	600
9	Total Dissolved Solids	200.0			500	2000
10	Iron (as Fe)	0.09			0.3	No relaxation
11	Fluoride (as F)	0.170			1.0	1.5
12		---				
13						
14						
15						
16						
17						
18						
19						
20						

- This report is restricted only for the sample /s submitted to this laboratory.
- It is presumed that the representative sample from the source is sent for analysis.
- This Sample /s is /are not collected by this laboratory.

(P.T.O.)

